



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2024-05-01	682	849	1531	7.80	1539	1666	127	234	1120	906	2260	96.7
2024-05-02	699	842	1541	8.46	1549	2043	494	234	1120	768	2122	97.6
2024-05-03	660	851	1511	6.67	1518	1951	434	238	1120	0	1358	97.2
2024-05-04	663	857	1520	4.96	1525	1796	271	239	1120	0	1359	96.8
2024-05-05	694	863	1557	5.58	1563	1795	233	227	1244	0	1471	96.2
2024-05-06	693	878	1570	8.42	1579	2066	487	240	1292	291	1823	96.7
2024-05-07	667	869	1536	9.55	1546	1750	204	240	1292	523	2055	96.3
2024-05-08	685	870	1556	7.55	1563	2010	447	238	1292	354	1884	96.5
2024-05-09	702	882	1584	9.86	1594	1866	272	240	1292	365	1897	96.5
2024-05-10	799	899	1698	7.90	1706	2093	388	237	1292	566	2095	96.6
2024-05-11	1178	906	2084	8.79	2093	2635	542	237	1292	185	1714	97.2
2024-05-12	798	945	1744	8.79	1752	1918	166	239	1292	0	1531	96.1
2024-05-13	700	941	1641	10.29	1651	2148	497	208	1192	706	2106	95.4
2024-05-14	713	917	1630	8.10	1638	1785	147	167	1574	1043	2784	97.0
2024-05-15	747	900	1647	7.65	1655	2021	367	171	1562	1001	2734	98.1
2024-05-16	806	889	1695	8.58	1704	2001	298	166	1550	970	2686	98.6
2024-05-17	736	866	1602	5.71	1608	2122	514	163	1551	487	2201	99.3
2024-05-18	681	833	1513	5.04	1519	1693	175	163	1554	0	1717	98.7
2024-05-19	730	839	1569	5.01	1574	2039	465	164	1536	0	1700	98.7
2024-05-20	790	853	1643	7.70	1651	1956	305	159	1508	0	1667	98.7
2024-05-21	701	877	1578	5.77	1584	1603	20	161	1507	0	1668	98.7
2024-05-22	715	860	1576	7.56	1583	1896	313	156	1519	0	1675	98.7
2024-05-23	756	878	1634	9.00	1643	1987	344	156	1525	0	1681	98.8
2024-05-24	702	876	1578	6.74	1585	1982	398	157	1524	0	1681	98.6
2024-05-25	693	880	1572	8.47	1581	1980	399	157	1522	0	1679	98.6
2024-05-26	740	868	1608	6.15	1614	1947	333	156	1520	0	1676	98.4
2024-05-27	746	900	1646	11.12	1657	1946	289	157	1519	0	1676	98.3
2024-05-28	721	892	1613	7.48	1620	1971	351	156	1509	0	1665	98.1
2024-05-29	778	919	1697	8.17	1705	2213	508	154	1516	0	1670	98.0
2024-05-30	797	921	1718	7.70	1726	2045	319	155	1516	0	1671	97.6
2024-05-31	740	964	1704	7.57	1712	1970	259	153	1515	0	1668	97.2

Min	660	833	1511	4.96	1518	1603		153	1120	0	1358	95.4
Avg	739	883	1622	7.68	1630	1964	334	191	1403	263	1857	97.6
Max	1178	964	2084	11.12	2093	2635		240	1574	1043	2784	99.3
Total m3	22915	27381	50295	238.13	50534	60894	10360	5922	43487	8163	57572	

↑
Cells will highlight red if volume is if above 3000 m3/ per day for DV.

17.01%
Loss

Full Level
End of Month
Average Month Volume

186,403
181,184
181,947

100.00%
97.2%