



Sheep River Regional Utility Corporation

Treated Daily Demand vs Raw Water Diversion

Year/Month/Day	Diamond Valley West Treated (m3/day)	Diamond Valley East Treated (m3/day)	Diamond Valley Total (m3/day)	Millarville Crossing Treated (m3/day)	Total Treated Water To Distribution (m3/day)	Raw Storage Water Used WTP (m3/day)	Process Loss (m3/day) Treated - Raw Used	Diamond Valley TW5A, CW8 Into Raw Water Reservoir (m3/day)	Diamond Valley VW5 Into Raw Water Reservoir (m3/day)	Stilling Basin Into Raw Water Reservoir (m3/day)	Total Into Raw Water Reservoir (m3/day)	Raw Water Storage Percentage
2025-03-01	631	1017	1648	4.33	1652	2130	478	0	1054	777	1831	93.8
2025-03-02	649	1016	1665	6.63	1672	2275	603	0	1054	779	1833	94.2
2025-03-03	604	1003	1607	6.99	1614	1878	264	0	1055	808	1863	94.0
2025-03-04	592	975	1568	7.56	1575	2034	459	0	1054	820	1874	94.4
2025-03-05	636	971	1607	7.40	1614	2114	500	0	1054	820	1874	94.7
2025-03-06	593	979	1572	5.79	1578	2072	494	0	1055	838	1893	94.7
2025-03-07	622	991	1613	6.16	1619	2195	576	0	1054	842	1896	94.8
2025-03-08	604	995	1599	6.22	1605	2099	494	0	1028	840	1868	94.8
2025-03-09	654	994	1648	6.09	1654	1932	278	0	970	840	1810	94.6
2025-03-10	593	1001	1594	7.46	1601	2175	574	0	968	841	1809	94.5
2025-03-11	629	996	1625	7.37	1632	2108	476	0	970	840	1810	94.5
2025-03-12	654	987	1641	7.10	1648	2085	437	0	970	845	1815	94.6
2025-03-13	618	990	1608	6.60	1615	2026	411	0	970	825	1795	94.5
2025-03-14	635	981	1616	6.76	1623	2240	617	0	970	821	1791	94.3
2025-03-15	606	1105	1711	4.40	1715	2141	426	0	971	822	1793	94.3
2025-03-16	652	1333	1985	7.04	1992	2244	252	0	989	821	1810	94.1
2025-03-17	604	1416	2020	8.66	2029	2821	792	0	987	881	1868	93.9
2025-03-18	635	1407	2042	7.15	2049	2421	372	0	987	906	1893	93.6
2025-03-19	625	1423	2048	6.09	2054	2428	374	0	987	907	1894	93.1
2025-03-20	616	1432	2048	8.36	2056	2945	889	0	983	906	1889	92.9
2025-03-21	641	1427	2068	6.21	2074	2389	315	0	970	908	1878	92.4
2025-03-22	633	1444	2077	6.13	2083	2596	513	0	969	907	1876	91.9
2025-03-23	654	1440	2094	8.91	2103	2697	594	0	971	907	1878	91.7
2025-03-24	637	1447	2084	8.08	2092	2607	515	0	927	969	1896	91.3
2025-03-25	630	1435	2065	7.75	2073	2492	419	59	923	992	1974	90.6
2025-03-26	654	1374	2028	8.86	2037	2761	724	125	936	1011	2072	91.0
2025-03-27	644	1359	2003	7.86	2011	2532	521	141	930	1073	2144	90.8
2025-03-28	631	1341	1972	8.25	1980	2302	322	152	932	1120	2204	90.7
2025-03-29	612	1341	1953	8.15	1961	2198	237	157	931	1120	2208	90.9
2025-03-30	647	1336	1983	7.48	1990	2273	283	160	930	1122	2212	90.9
2025-03-31	625	1357	1982	7.40	1989	2084	95	159	930	1121	2210	91.0
Min	592	971	1568	4.33	1575	1878		0	923	777	1791	90.6
Avg	628	1204	1831	7.07	1838	2300	461	31	983	904	1918	93.1
Max	654	1447	2094	8.91	2103	2945		160	1055	1122	2212	94.8
Total m3	19458	37314	56771	219.25	56991	71294	14303	953	30479	28027	59459	

↑
Cells will highlight red if volume is if above
3000 m3 per day for DV.

20.06%
Loss

Full Level
End of Month
Average Month Volume

186,403
169,627
173,625

100.00%
91.0%